



**Neschen Coating GmbH**  
**Hans-Neschen-Straße**  
**31675 Bückeburg**  
**Germany**

**Your message - reference**

-

**our reference**

JW/4041

**Gent**

2023-11-17

Certification report 23/4041

---

## 1. Description of the product:

<b>Product family</b>	Decorative wallcovering made of non-woven fabric and PVC-free surface
<b>Total mass</b>	170 - 215 g/m <sup>2</sup>
<b>Thickness</b>	0.22 mm

## 2. Test results:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

**CENTEXBEL • textile competence centre • [www.centexbel.be](http://www.centexbel.be)**

**GENT • Technologiepark 70 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • [gent@centexbel.be](mailto:gent@centexbel.be)**

**VAT • BE 0459.218.289 • IBAN • BE 44 2100 4729 6545 • BIC • GEBABEBB**

**addressee**

Neschen Coating GmbH

**our reference**

JW/4041

**Gent**

2023-11-17

**page**

2

### 3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows according EN 13501-1:2018:

**C – s1, d0**

*if glued to substrates having a Euroclass A2-s1,d0 or A1 which density is superior to 525kg/m<sup>3</sup>*

**Related commercial names to this product group**

NESCHEN wallpaper LITE smooth  
NESCHEN wallpaper LITE sand  
NESCHEN wallpaper L-UV sand

**The obtained classification is based on the next test reports**

CREPIM: DO-23-5294\A-R1 dd 09-11-2023

**Validity of the certificate**

08-11-2028

Jo Wynendaele, PhD

Consultant Floor and Wall Coverings

